AUTOMATIC WET PIPE	Property Address: 718 Vincent Ave Bx, NY 10465
SPRINKLER SYSTEM	Inspector: <u>Stephen T Dziuma</u> Inspector #: 91423005 Expires; 10 <u>/06/2024</u>
SPRIINKLER STSTEIVI	Inspector #. <u>91423005</u> Expires; 10/06/2024
	Inspection Date: 11/7/2021
This Report covers:MonthlyQuarterly	Annual3 Year5 Year
MONTHLY INSPECTION; Ala	rm Valves;
Gauges – normal water pressure maintained	IAfree of damage
<u>—</u>	IAaccessible
_	<u>IA</u> retard chamber/alarms drains not leaking
<u>√</u> in correct (open or closed) position <u>√</u> sealed, locked or supervised	
✓ scaled, locked of supervised	
free from damage or leaks	
QUARTERLY INSPECTION;	FIRE DEPARTMENT CONNECTIONS;
<u>NA</u> alarm devices – free of damage <u>NA</u> hydraulic data nameplate – securely attached to riser/legible	
PRESSURE REDUCING VALVE;	<u>NA</u> plugs/caps in place
<u>NA</u> in the open position/not leaking	<u>NA</u> gaskets are not damaged
<u></u> maintaining downstream pressure-	<u>NAidentification signs are in place</u>
	<u>NAball drip valve if functioning</u>
QUARTERLY TEST;	
main drain test – if sole supply is through backflow preventer	NAalarm devices – water motor gong
SEMI-ANNUAL TEST	
supervisory switch functions	alarm devices
· · · · · · · · · · · · · · · · · · ·	
ANNUAL INSPECTION SPRINKLERS (VISIBLE);	installed in proper orientation
free of corrosion; foreign material or paint	installed in proper orientation
PIPING AND FITTINGS	
in good condition/no external corrosion	NAhose racks – inspected per NFPA 1962 –
no leaks or mechanical damage	
correct alignment – no external loads	
ANNUAL TEST;	
MAIN DRAIN TEST	
Staticpsi Residualpsi results do not differ by more than 10% from previous test?	
all control valves through full range of motion and returned to n	
Specific gravity or anti-freeze system (if present)	
Backflow preventer – test <u>NA</u>	
Backflow preventer – flow test <u>NA</u>	
THREE YEAR TEST:	
hose has been tested in accordance with NFPA 1962	
FIVE YEAR INSPECTION;	FIVE YEAR TEST;
alarm valve interior including strainers, filters, and restriction of	
check valve – internal moves freely, in good condition obstruction inspection – no foreign or obstructing material fou	pressure reducing valve - flow test and comparable-
ROUTINE MAINTAINANCE	
sprinklers tested or replaced per appropriate testing schedule	
COMMENTS; Static PSI 41	
Signature	Date 11/7/2021

Certificate number: 91413005	expiration: <u>10/06/2024</u>
certificate framber. <u>51415005</u>	cxpiration. <u>10/00/2024</u>