AUTOMATIC WET PIPE	Property Address: 718 Vincent Ave Bx, NY 10465
SPRINKLER SYSTEM	Inspector: <u>Stephen T Dziuma</u> Inspector #: <u>91423005</u> Expires; 10/06/2024
	Inspection Date: 9/6/2022
This Report covers: <u>√</u> MonthlyQuarterly	Annual3 Year5 Year
	m Valves;
	Afree of damage Aaccessible
	<u>A</u> retard chamber/alarms drains not leaking
$\{v}$ in correct (open or closed) position	
sealed, locked or supervised	
$\underline{\qquad}$ accessible	
free from damage or leaks	
QUARTERLY INSPECTION;	FIRE DEPARTMENT CONNECTIONS;
<u>NA</u> alarm devices – free of damage	
<u>NAhydraulic data nameplate – securely attached to riser/legible</u>	
PRESSURE REDUCING VALVE;	<u>NAplugs/caps in place</u>
<u>NA</u> in the open position/not leaking NAmaintaining downstream pressure-	<u>—NA</u> gaskets are not damaged —NA identification signs are in place
	<u>NA</u> ball drip valve if functioning
QUARTERLY TEST;	
main drain test - if sole supply is through backflow preventer	<u>NAalarm devices – water motor gong</u>
staticPSI residualPSI	
SEMI-ANNUAL TEST	
	alarm devices – inspectors test or bypass opened/obstructed water flow
ANNUAL INSPECTION SPRINKLERS (VISIBLE);	
no damage or leaks	installed in proper orientation
free of corrosion; foreign material or paint PIPING AND FITTINGS	_
in good condition/no external corrosion	<u>NAhose racks – inspected per NFPA 1962</u>
no leaks or mechanical damage	building wet piping not exposed to freezing temocrature –
<u>correct alignment – no external loads</u>	
ANNUAL TEST;	
MAIN DRAIN TEST Static psi Residual psi results do i	not differ by more than 10% from previous test?
psipsipsipsi	
Specific gravity or anti-freeze system (if present)	
Backflow preventer test <u>NA</u>	
Backflow preventer – flow test <u>NA</u>	
THREE YEAR TEST:	
hose has been tested in accordance with NFPA 1962	
FIVE YEAR INSPECTION;	FIVE YEAR TEST;
alarm valve interior including strainers, filters, and restriction o	
check valve - internal moves freely, in good condition	
obstruction inspection = no foreign or obstructing material four ROUTINE MAINTAINANCE	nd to previous results
COMMENTS; Static PSI 44	
Signature	Date 9/6/2022
Certificate number: <u>91413005</u> expiration: <u>10/06/2024</u>	

Certificate number: 91413005	expiration: 10/06/2