AUTOMATIC WET PIPE	Property Address: 718 Vincent Ave Bx, NY 10465
SPRINKLER SYSTEM	Inspector: <u>Stephen T Dziuma</u> Inspector #: <u>91423005</u> _{Expires; 10/06/2024}
	Inspection Date: 11/2/2022
This Report covers: <u>√</u> MonthlyQuarterly	Annual3 Year5 Year
MONTHLY INSPECTION; Alar	rm Valves;
	IAfree of damage
	IAaccessible IAretard_chamber/alarms_drains_not_leaking
in correct (open or closed) position	
✓ sealed, locked or supervised	
accessible	
<u> </u>	
QUARTERLY INSPECTION; 	FIRE DEPARTMENT CONNECTIONS;
<u>NA</u> aiarm devices – tree of damage <u>NA</u> hydraulic data nameplate – securely attached to riser/legible	— NA visible and accessible — MA couplings/swivels operate correctly
PRESSURE REDUCING VALVE;	<u>NA</u> plugs/caps in place
NAin the open position/not leaking	<u>NA</u> gskets are not damaged
<u>NA</u> maintaining downstream pressure-	<u>—NA</u> identification signs are in place
	<u>—NA</u> ball drip valve if functioning
QUARTERLY TEST;	
main drain test – if sole supply is through backflow preventer	<u>NA</u> alarm devices – water motor gong
staticPSI residualPSI	
SEMI-ANNUAL TEST	
supervisory switch functions	alarm devices
ANNUAL INSPECTION SPRINKLERS (VISIBLE); no damage or leaks	installed in proper orientation
free of corrosion; foreign material or paint	installed in proper orientation
PIPING AND FITTINGS	
in good condition/no external corrosion	<u>NAhose racks – inspected per NFPA 1962</u>
no leaks or mechanical damage	building wet piping not exposed to freezing temoerature
correct alignment – no external loads	
ANNUAL TEST;	
MAIN DRAIN TEST	
Staticpsi Residualpsiresults do	not differ by more than 10% from previous test?
all control valves through full range of motion and returned to n	ormal position
Specific gravity or anti-freeze system (if present)	
Backflow preventer – test <u>NA</u> Backflow preventer – flow test – NA	
Backnow preventer – now test – $\frac{NA}{N}$	
THREE YEAR TEST:	
hose has been tested in accordance with NFPA 1962	
FIVE YEAR INSPECTION; alarm valve interior including strainers, filters, and restriction o	FIVE YEAR TEST; rifice
during value interior including settines, inters, and restriction of check value – internal moves freely, in good condition	pressure reducing valve - flow test and comparable-
obstruction inspection - no foreign or obstructing material four	
ROUTINE MAINTAINANCE	
sprinklers tested or replaced per appropriate testing schedule	
COMMENTS: Static DSI 42	
COMMENTS; Static PSI 43	
Signature	Date 11/2/2022

Certificate number: <u>91413005</u> expiration: <u>10/06/2024</u>